

Jonathan Rankin  
South Lodge  
Cameron House Estate Track  
Alexandria  
G83 8QZ

Date: 10th January 2024

Dear Sir/Madam

**LICENSING CONSULTATION**

**Reference Number:** LIC/23/0172  
**Description:** FW: WD-00093-P - STL Application South Lodge, Old Luss Road, Balloch  
G83 8QP - consultation  
**Location:** South Lodge Cameron House Estate Track Alexandria G83 8QZ

Building Standards has the following comments on this consultation:

No Completion has been obtained for BW/15/121 Single storey side extension.  
The Building Warrant expired on 9/6/18. An extension to the validity of the building warrant is required before the completion application can be submitted.  
Provide current layout of property indicating fire detection, escape routes and mechanical extract fans.

Yours faithfully

*Lorraine Charles*

Building Standards Surveyor